

AQUA-AIR MANUFACTURING - JAMES D. NALL CO.,INC.
 COOLING LOAD CALCULATION FOR QUOTE 02110701
 COMPANY:
 DATE: 07/08/03

1. COOLING FACTOR
2. TEMPERATURE MULTIPLIER
3. OA OCCUPANCY FACTOR
4. OACFM-OCCUPANCY
5. OACFM-AIR CHANGES
6. ACTUAL OACFM USED

	1	2	3	4	5	6		
0 PILOTHOUSE AFT	20	1	H	120	159	340	63840	AREA LOAD
...PEOPLE:	8						-6242	OA COOLING, BTUH
...AREA:	456						57597	F/C CAPACITY REQ
...AREA HT:	7							
...VOLUME:	3192							
1 GALLEY//LOUNGE PORT	18	1	H	450	98	400	35280	AREA LOAD
...PEOPLE:	30						-7344	OA COOLING, BTUH
...AREA:	280						27936	F/C CAPACITY REQ
...AREA HT:	7							
...VOLUME:	1960							
2 GALLEY//LOUNGE STBD	18	1		450		0	35280	AREA LOAD
...PEOPLE:							0	OA COOLING, BTUH
...AREA:	280						35280	F/C CAPACITY REQ
...AREA HT:	7							
...VOLUME:	1960							
3 PORT H'WAY	18	1	L	80	17	80	9450	AREA LOAD
...PEOPLE:	4						-1468	OA COOLING, BTUH
...AREA:	75						7981	F/C CAPACITY REQ
...AREA HT:	7							
...VOLUME:	525							
4 STBD H'WAY	18	1	L	80	17	80	9450	AREA LOAD
...PEOPLE:	4						-1468	OA COOLING, BTUH
...AREA:	75						7981	F/C CAPACITY REQ
...AREA HT:	7							
...VOLUME:	525							
5 PORT HEAD	18	1		80		0	5670	AREA LOAD
...PEOPLE:							0	OA COOLING, BTUH
...AREA:	45						5670	F/C CAPACITY REQ
...AREA HT:	7							
...VOLUME:	315							
6 PORT STRM 1	18	1	L	40	11	60	6300	AREA LOAD
...PEOPLE:	2						-1101	OA COOLING, BTUH

...AREA:	50					5198	F/C CAPACITY REQ
...AREA HT:	7						
...VOLUME:	350						
7 PORT STRM 2	18	1 L	40	11	60	6300	AREA LOAD
...PEOPLE:	2					-1101	OA COOLING, BTUH
...AREA:	50					5198	F/C CAPACITY REQ
...AREA HT:	7						
...VOLUME:	350						
8 PORT STRM 3	18	1 L	40	11	60	6300	AREA LOAD
...PEOPLE:	2					-1101	OA COOLING, BTUH
...AREA:	50					5198	F/C CAPACITY REQ
...AREA HT:	7						
...VOLUME:	350						
9 MID STRM 1	18	1 L	40	11	60	6300	AREA LOAD
...PEOPLE:	2					-1101	OA COOLING, BTUH
...AREA:	50					5198	F/C CAPACITY REQ
...AREA HT:	7						
...VOLUME:	350						
10 MID STRM 2	18	1 L	40	11	60	6300	AREA LOAD
...PEOPLE:	2					-1101	OA COOLING, BTUH
...AREA:	50					5198	F/C CAPACITY REQ
...AREA HT:	7						
...VOLUME:	350						
11 STBD HEAD	18	1	40		0	5670	AREA LOAD
...PEOPLE:						0	OA COOLING, BTUH
...AREA:	45					5670	F/C CAPACITY REQ
...AREA HT:	7						
...VOLUME:	315						
12 STBD STRM 1	18	1 L	40	11	60	6300	AREA LOAD
...PEOPLE:	2					-1101	OA COOLING, BTUH
...AREA:	50					5198	F/C CAPACITY REQ
...AREA HT:	7						
...VOLUME:	350						
13 STBD STRM 2	18	1 L	40	11	60	6300	AREA LOAD
...PEOPLE:	2					-1101	OA COOLING, BTUH
...AREA:	50					5198	F/C CAPACITY REQ
...AREA HT:	7						
...VOLUME:	350						
14 STBD STRM 3	18	1 L	40	11	60	6300	AREA LOAD
...PEOPLE:	2					-1101	OA COOLING, BTUH
...AREA:	50					5198	F/C CAPACITY REQ
...AREA HT:	7						
...VOLUME:	350						

15 PORT MACHINERY ROOM	15	1	40	0	25200	AREA LOAD
...PEOPLE:					0	OA COOLING, BTUH
...AREA:	240				25200	F/C CAPACITY REQ
...AREA HT:	7					
...VOLUME:	1680					
16 STBD MACHINERY ROOM	15	1	40	0	25200	AREA LOAD
...PEOPLE:					0	OA COOLING, BTUH
...AREA:	240				25200	F/C CAPACITY REQ
...AREA HT:	7					
...VOLUME:	1680					

265440 ----- COOLING LOAD, BTU/H
 1050 ----- OACFM-OCCUPANCY
 379 ----- OACFM-AIR CHANGES
 1380 ----- RECOMMENDED OACFM
 25336 ----- COOLING CAPACITY OF OUTSIDE AIR, BTU/H
 14952 ----- INTERIOR VOLUME, CU.FT.

REQUIRED CHILLER CAPACITY IN TONS, @ 80% DIVERSITY: 16.0

TOTAL CHILLER CAPACITY REQUIRED, TONS: 31.1

QTCCRSS.FLX

□